

Gilbert-Summit Rural Water District System # 3220001 2023 WATER QUALITY REPORT



Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is groundwater and comes from eight wells permitted by the South Carolina Department of Health and Environmental Control (SCDHEC). They are located at a specific depth within the Middendorf Aquifer. This aquifer lies in the Coastal Plain of our state.

Source water assessment and its availability

A Source Water Assessment was completed in June 2006 by SCDHEC. This was done to identify potential contaminant sources (PCS). This revealed 13 PCS. A copy of this assessment is available for your review on our website at <u>https://www.gsrwater.com/reports/</u>. If you do not have internet access, please contact Marty Gassaro at (803) 892-5544 to make arrangements to review this document.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have any questions about this report or concerning your water utility, please contact Marty Gassaro, Water District Manager, at (803) 892-5544. Information is also available on our website at <u>www.gsrwater.com</u>. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC 29054.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Gilbert-Summit Rural Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report.

	Detect Ran		lange								
	MCI or	.G N T	MCL, FT, or	In Your			Sample				
Contaminants	MRD	LG	MRDL	Water	Lov	w High	Date	Viola	tion	Typical Source	
Disinfectants & Disinfection By-Products											
(There is convincing evi	idence	that ac	ddition	of a disint	fecta	ant is ne	cessary fo	or cont	trol of	microbial contaminants)	
Chlorine (as Cl2) (ppm)	4		4	1.03	0.7	5 1.32	2023	N	0	Water additive used to control microbes	
TTHMs [Total Trihalomethanes] (ppb)	NA		80	ND	NE	ND	2023	N	o []	By-product of drinking water disinfection ND=Non-Detect)	
Inorganic Contaminan	its			•			•				
Barium (ppm)	2		2	0.06	0	0.06	2022	N	o []	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Fluoride (ppm)	4		4	1.1	0	1.1	2022	No	0] t	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
Nitrate [measured as Nitrogen] (ppm)	10		10	5.0	0	5.4	2023	N	o []	unoff from fertilizer use; Leaching from eptic tanks, sewage; Erosion of natural eposits	
Sodium (ppm)	NA		NA	22	5.3	22	2022	No	o]	Erosion of natural deposits	
Radioactive Contamin	ants										
Radium (combined 226/228) (pCi/L)	0		5	4.00	0	4.88	2023	N	o]	Erosion of natural deposits.	
Beta/photon emitters	0		50*	7.06	0	8.06	2023	N	o]]	Decay of man-made and natural deposits	
Gross Alpha (pCi/L)	0		15	6.00	0	6.89	2023	N	o]	Erosion of natural deposits	
Contaminants		MCLG A		90th Percentile		Sample Date	# Sampl Exceedin AL	les ng Ex	xceeds AL	S Typical Source	
Inorganic Contaminan	its										
Copper - action level at consumer taps (ppm)		1.3	1.3	0.903		2022	1	No		Corrosion of household plumbing systems; Erosion of natural deposits	
Inorganic Contaminan	its										
Lead - action level at consumer taps (ppb)		0	15	7		2022	2		No	Corrosion of household plumbing systems; Erosion of natural deposits	

*The MCL for beta particle results is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles. Because the beta particle results were below 50 pCi/L, no testing for individual beta particle constituents was required.

Coliform Bacteria						
MCLG	Total Coliform MCL	Highest No. of Positive	Fecal Coliform or E. Coli MCL	Total No. of Positive E.Coli or Fecal Coli Samples	Violation	Likely Source of Contamination
0	0 positive monthly sample	0	0	0	Ν	Naturally present in the environment

Unit Descriptions				
Term	Definition			
ppm	ppm: parts per million, or milligrams per liter (mg/L)			
ppb	ppb: parts per billion, or micrograms per liter (μ g/L)			
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)			
NA	NA: not applicable			
ND	ND: Not detected			

Important Drinking Water Definitions					
Term	Definition				
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.				
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.				
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.				
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.				
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.				
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.				
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.				

If you have any questions about this report or concerning your water utility, please contact Marty Gassaro, Water District Manager, at (803) 892-5544. Information is also available on our website at <u>www.gsrwater.com</u>. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC, 29054.

For more information please contact:

Contact Name: Marty Gassaro Address: PO Box 172 136 Hampton St. Gilbert, SC 29054 Phone: (803) 892-5544

System # 3220001



P O Box 172 Gilbert, South Carolina 29054 RETURN SERVICE REQUESTED

PRESORTED FIRST CLASS MAIL U.S. POSTAGE PAID LEESVILLE, SC 29070 Permit #3