



Gilbert-Summit Rural Water District
System # 3220001
2025 WATER QUALITY REPORT



Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is groundwater and comes from eight wells permitted by the South Carolina Department of Environmental Services (SCDES). They are located at a specific depth within the Middendorf Aquifer. This aquifer lies in the Coastal Plain of our state.

Source water assessment and its availability

A Source Water Assessment was completed in June 2006 by SCDHEC (now SCDES). This was done to identify potential contaminant sources (PCS). This revealed 13 PCS. A copy of this assessment is available for your review on our website at www.gsrwater.com/reports. If you do not have internet access, please contact Marty Gassaro at (803) 892-5544 to make arrangements to review this document.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have any questions about this report or concerning your water utility, please contact Marty Gassaro, Water District Manager, at (803) 892-5544. Information is also available on our website at www.gsrwater.com. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC 29054.

Additional Information for Lead

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Gilbert-Summit Rural Water District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the Gilbert-Summit Rural

Water District at 803-892-5544. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Health Effects of Lead in Drinking Water

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risk of hear disease, high blood pressure, kidney or nervous system problems.

Health Effects of Nitrate in Drinking Water

Nitrate in drinking water at levels of 10 ppm is a health risk for infants less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice of your health care provider.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	LRAA	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1	0.69	1.66	2025	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	60	57	7	63.1	2025	No	By-product of drinking water disinfection (ND=Non-Detect)
HAA5 (ppb)	NA	80	9	0	12.7	2025	No	By-product of drinking water disinfection (ND=Non-Detect)
Inorganic Contaminants								
Barium (ppm)	2	2	0.061	0	0.061	2025	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	1.1	0	1.1	2025	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	5.0	0	5.4	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	NA	NA	22	3.8	23	2025	No	Erosion of natural deposits
Radioactive Contaminants								

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	LRAA	Range		Sample Date	Violation	Typical Source
				Low	High			
Radium (combined 226/228) (pCi/L)	0	5	6.00	0	6.50	2025	No	Erosion of natural deposits.
Beta/photon emitters	0	50*	10.80	0	10.80	2025	No	Decay of man-made and natural deposits
Gross Alpha (pCi/L)	0	15	10.00	0	17.50	2025	No	Erosion of natural deposits
Uranium (ug/L)	0	30	8.00	0	5.20	2025	No	Erosion of natural deposits

Contaminants	MCLG	AL	90th Percentile	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Copper - action level at consumer taps (ppm) Copper Range: 0.015–0.666 PPB	1.3	1.3	0.245	2025	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb) Lead Range: 0-3 PPM	0	15	2.000	2025	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

The EPA has required Public Water Systems such as the Gilbert-Summit Rural Water District to conduct an inventory of all service materials within their boundaries in an effort to identify, and eventually remove, the potential causes of lead in drinking water. Access to this inventory can be found on our website at <https://www.gsrwater.com/lead-and-copper-rule/>.

*The MCL for beta particle results is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles. Because the beta particle results were below 50 pCi/L, no testing for individual beta particle constituents was required.

Unregulated Contaminants

Unregulated contaminants are those for which U.S. EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of these contaminants in drinking water and whether future regulation is warranted. In 2024, Gilbert-Summit Rural Water District participated in the fifth round of the Unregulated Contaminant Monitoring Rule (UCMR5). For a copy of the results, please contact Marty Gassaro, District Manager, at (803) 892-55454.

Contaminants (units)	Sample Year	Average Level Found	Range of Detections
Lithium (ppb)	2024	11.85	0 – 49.4

Coliform Bacteria						
MCLG	Total Coliform MCL	Highest No. of Positive	Fecal Coliform or E. Coli MCL	Total No. of Positive E.Coli or Fecal Coli Samples	Violation	Likely Source of Contamination
0	0 positive monthly sample	0	0	0	N	Naturally present in the environment

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

If you have any questions about this report or concerning your water utility, please contact Marty Gassaro, Water District Manager, at (803) 892-5544. Information is also available on our website at www.gsrwater.com. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC, 29054.

For more information please contact:

Contact Name: Marty Gassaro
Address: PO Box 172
136 Hampton St.
Gilbert, SC 29054
Phone: (803) 892-5544

System # 3220001

