



LEAD AND COPPER SAMPLING RESULTS

June - September 2025 90TH PERCENTILE

SC3220001 GILBERT-SUMMIT WD (3220001)

Below are the individual results for each sample site from the June - September 2025 monitoring period.
The 90th percentile for lead was 0.002 mg/L and for copper 0.245 mg/L for the 20 samples analyzed.

The public water system must deliver Customer Notice of Lead and Copper Results in Drinking Water within 30 days of receiving these test results from DHEC. This notice must contain the content as outlined in State Primary Drinking Water Regulation R.61-58.11.G(4)(c):

- the results of lead tap water monitoring for the tap that was tested
- an explanation of the health effects of lead
- list steps consumers can take to reduce exposure to lead in drinking water
- contact information for the water utility
- the maximum contaminant level goal and the action level for lead and the definitions for these two terms from R.61-58.12.C(3).

As per R.61-58.11.G(4)(d) the consumer notice must be provided to persons served at the tap that was tested, either by mail or by another method approved by the Department. For example, upon approval by the Department, a non-transient non-community water system could post the results on a bulletin board in the facility to allow users to review the information. The system must provide the notice to customers at sample taps tested, including consumers who do not receive water bills. After notification is completed the Consumer Information Notice Form must be filled out and returned to DHEC.

The next sampling schedule is 20 samples to be collected during the 06/01/2028 - 09/30/2028 monitoring period.

T-CODE	DESCRIPTION	COLLECTION DATE	LEAD (mg/L)	COPPER (mg/L)
T3A0002	401 SHADY GROVE RD.	8/20/2025	0	0.026
T3A0003	358 CACTUS RD.	8/21/2025	0	0.057
T3A0004	2423 LEWIE RD.	8/20/2025	0	0.081
T3A0005	2142 PRICEVILLE RD.	8/20/2025	0.002	0.666
T3A0006	128 DIXIE ST.	8/21/2025	0	0.042
T3A0007	302 REEDER ST.	8/20/2025	0	0.042
T3A0008	433 PEACH FESTIVAL RD	8/20/2025	0	0.111
T3A0009	129 W. HAMPTON ST.	8/20/2025	0	0.02
T3A0012	140 PEACHTREE ST.	8/19/2025	0	0.02
T3A0014	176 HAPTON ST.	8/20/2025	0	0.017
T3A0015	203 BROAD ST.	8/20/2025	0.003	0.015
T3A0016	2819 PRICEVILLE RD.	8/20/2025	0.002	0.034
T3A0017	2100 PRICEVILLE RD.	8/20/2025	0	0.178
T3A0018	4236 AUGUSTA HWY.	8/20/2025	0	0.072
T3A0020	314 WIRE RD.	8/26/2025	0	0.176
T3A0023	216 JUNIPER SPRINGS R	8/25/2025	0	0.053
T3A0201	2433 LEWIE RD.	8/20/2025	0	0.024
T3A0501	209 BROAD STREET	8/25/2025	0	0.479

If you have any questions or concerns contact one of the DHEC staff members below.

Idris Liban
 Env. Health Manager
 Office:(803)898-3573
 Idris.Liban@des.sc.gov

SCDES
 Bureau of Water
 Fax:(803)898-3795
 2600 Bull Street
 Columbia, SC29201



LEAD AND COPPER SAMPLING RESULTS

June - September 2025 90TH

PERCENTILE

SC3220001 GILBERT-SUMMIT WD (3220001)

T-CODE	DESCRIPTION	COLLECTION DATE	LEAD (mg/L)	COPPER (mg/L)
T3A2201	322 HAMPTON ST	8/22/2025	0.003	0.093
T3A2501	2208 LEWIE RD	8/22/2025	0	0.245
90th Percentile			0.002 mg/L	0.245 mg/L